

Message

---

**Sent:** 3/21/2019 12:39:57 PM  
**To:** Konkus, John [konkus.john@epa.gov]; Grantham, Nancy [Grantham.Nancy@epa.gov]; Lyons, Troy [lyons.troy@epa.gov]; Palich, Christian [palich.christian@epa.gov]; Frye, Tony (Robert) [frye.robert@epa.gov]; McFaul, Jessica [mcfaul.jessica@epa.gov]; Abboud, Michael [abboud.michael@epa.gov]; Hewitt, James [hewitt.james@epa.gov]; Schiermeyer, Corry [schiermeyer.corry@epa.gov]  
**Subject:** HEADS UP - International Terminals Corporation Fire

All – Elevated readings for benzene (about 1.8 ppm) in areas around the facility in early morning hours.

City of Deer Park has issued voluntary shelter-in-place (about 30,000 people). Reportedly, schools cancelled in several nearby towns also.

ITC believes vapors are from one of the damaged tanks. Tank volume will be transferred to create headroom for vapor suppression foam. Material will be temporarily moved to secondary containment which is currently foamed. Hope to begin emptying tank later today.